DECLARATION OF CONFORMITY CE Kanlux

Kanlux S.A., ul.Objazdowa 1-3, 41-922 Radzionków, (Poland) herewith declares that the product:

RESIDUAL CURRENT CIRCUIT BREAKERS

Type / types: KR6 25/x/2, KR6 40/x/2, KR6 63/x/2,

KR6 25/x/4, KR6 40/x/4, KR6 63/x/4

x = 003, 01, 03

Trade mark: Kanlux

Basic parameters: $Uc = 230V \sim (1P+N), 400V \sim (3P+N); In = 25A, 40A, 63A; I\Delta n = 0.03A, 0.1A, 0.3A;$

typ A i AC; $Inc = I\Delta c = 6kA$; $Im = I\Delta m = 630A$ (63A), 500A (25A, 40A)

is in conformity with the provisions of the following EC directive(s)

(including all applicable amendments):

Directive (LVD) - 2006/95/EEC

References of standards and/or technical specifications applied for this declaration of conformity:

EN 61008-1:1994/A14:1998/A17:2000

Residual current operated circuit-breakers without integral overcurrent protection for household and similar uses (RCCB's) - Part 1: General rules.

EN 61008-2-1:1994/A11:1998

Residual current operated circuit-breakers without integral overcurrent protection for household and similar uses (RCCB's) - Part 2-1: Applicability of the general rules to RCCB's functionally independent of line voltage.

ID 0177, S.CE/101, NWP/073

Last two digits of the year in which the CE marking was affixed: 07

Radzionków, 01.09.2007

Z-ca Dyrektora Importu ds. Przygotowania Sprzedaży Michał Sztuka name and function of the signatory

Kanlux S.A.